

# Wagner & Bonsignore

Consulting Civil Engineers, A Corporation

Nicholas F. Bonsignore, P.E.  
Robert C. Wagner, P.E.  
Paula J. Whealen  
Henry S. Matsunaga

Andrew T. Bambauer, P.E.  
John Faux, P.E.  
David Houston, P.E.  
David P. Lounsbury, P.E.  
Emily MacDonald  
Ryan E. Stolfus

October 22, 2009

James C. Hanson  
Consulting Civil Engineer  
A Corporation

Ms. Marina West, General Manager, PG  
Bighorn-Desert View Water Agency  
622 South Jemez Trail  
Yucca Valley CA 92284

**Re: Ames Valley Water Basin Monitoring Program dated March, 2009**

Dear Ms. West,

Enclosed for your records is Addendum No. 1 to the January 2008 through December 2008 Ames Valley Water Basin Monitoring Program. The addendum includes a revised cover sheet and water quality data for Well 24E which was provided by Hi-Desert Water District but inadvertently omitted from the 2008 report. Please note that for the Ames Basin reports covering 2005, 2006 and 2007, we did not receive water quality data from Hi-Desert Water District.

Please call if you have any questions.

Very truly yours,  
WAGNER AND BONSIGNORE  
CONSULTING CIVIL ENGINEERS



By: Emily MacDonald

Via: U.S. Mail

HDWME.100.PDF

**HI-DESERT WATER DISTRICT  
BIGHORN-DESERT VIEW WATER AGENCY**

**ADDENDUM 1**

**Including Water Quality Data for Well 24E**

**AMES VALLEY WATER BASIN  
MONITORING PROGRAM**

**FOR THE PERIOD  
JANUARY 2008 THROUGH DECEMBER 2008**

OCTOBER 2009

Wagner and Bonsignore,  
Consulting Civil Engineers

# APPENDIX D

Revised 10/2009

## AMES VALLEY WATER BASIN MONITORING PROGRAM WATER QUALITY DATA

MAP POINT	BDVWA DESIGNATIONS
1	Gubler H-1 (no data)
16	BDV #2
15	BDV #3
17	BDV #4 (no data)
5	BDV #6
6	BDV #7
12	BDV #8
4	BDV #9 (no data)
8	CSA W-1 #1
9	CSA W-1 #2
21	HD #10 (no data)
11	HD #24



**E.S.BABCOCK & Sons, Inc.**  
Environmental Laboratories *est. 1906*

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99) EDT

Date of Report: 09/01/13 Sample ID No. A8L2460-01  
 Laboratory Project  
 Name: E.S. Babcock & Sons, Inc. Manager: Mary Mazurkiewicz For Lorenzo (Z)  
 Name of Sampler: Mark Ban Employed By: ~~Rodriguez~~ HDWD  
 Date/Time Sample Date Analyses  
 Collected: 08/12/23 09:16 Received @ Lab: 08/12/23 14:45 Completed: 09/01/10

System System  
 Name: HI DESERT WD Number: 3610073  
 Name or Number of Sample Source: WELL 24E

```

*****
* User ID: TAN Station Number: 3610073-023
* Date/Time of Sample: 08/12/23 09:16 Laboratory Code: 4790
* YY MM DD TTTT YY MM DD
* Date Analyses Completed: 09/01/10
* Submitted by: _____ Phone # _____
*****
  
```

MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
	mg/L	Total Hardness	00900	140	
	mg/L	Calcium	00916	44	
	mg/L	Magnesium	00927	8.1	
	mg/L	Sodium	00929	37	
	mg/L	Potassium	00937	2.1	
Total Cations		Me/L Value		4.54	
	mg/L	Total Alkalinity	00410	180	
	mg/L	Hydroxide	71830	< 3	
	mg/L	Carbonate	00445	< 3	
	mg/L	Bicarbonate	00440	210	
*	mg/L+	Sulfate	00945	22	0.50
*	mg/L+	Chloride	00940	11	
45	mg/L	Nitrate	71850	4.9	2.0
Total Anions		Me/L Value		4.29	
2	** mg/L	Fluoride	00951	0.7	0.1
Total Anions + Fluoride		Me/L Value		4.33	
9	Std.Units	pH	00403	7.8	
***	umho/cm	Specific Conductance	00095	420	
****	mg/L+	Total Dissolved Solids	70300	240	
15	Units	Color	00081	< 3	
3	TON	Odor	00086	< 1	1.0
5	NTU	Turbidity	82079	< 0.2	



**E.S.BABCOCK & Sons, Inc.**  
Environmental Laboratories *est. 1906*

Page 2 of 2- Mineral, Physical and Inorganic Chemicals Form

Sample ID No. A8L2460-01

MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
0.5	mg/L+	MBAS	38260	< 0.05	
INORGANIC CHEMICALS					
1000	ug/L	Aluminum	01105	< 50	50
6	ug/L	Antimony	01097	< 6	6.0
10	ug/L	Arsenic	01002	2	2.0
1000	ug/L	Barium	01007	< 100	100
4	ug/L	Beryllium	01012	< 1	1.0
5	ug/L	Cadmium	01027	< 1	1.0
50	ug/L	Total Chromium (also used for Cr+6 screen)	01034	4.1	1.0
1000	ug/L+	Copper	01042	< 50	50
300	ug/L+	Iron	01045	< 100	100
15	ug/L	Lead	01051	< 5	5.0
50	ug/L+	Manganese	01055	< 20	20
2	ug/L	Mercury	71900	< 1	1.0
100	ug/L	Nickel	01067	< 10	10
50	ug/L	Selenium	01147	< 5	5.0
100	ug/L+	Silver	01077	< 10	10
2	ug/L	Thallium	01059	< 1	1.0
5000	ug/L	Zinc	01092	< 50	50
ADDITIONAL ANALYSES					
6	ug/L	Perchlorate	A-031	< 4	4.0
	ug/L	Cyanide	01291	< 100	100
1000	ug/L	Nitrite as N	00620	< 100	100

\* 250-500-600    \*\* 0.6-1.7    \*\*\* 900-1600-2200    \*\*\*\* 500-1000-1500    + Indicates Secondary Drinking Water Standards

Page 3 of 8 of Complete Report

*mailing*  
P.O. Box 432  
Riverside, CA 92502-0432

*location*  
6100 Quail Valley Court  
Riverside, CA 92507-0704

P 951 653 3351  
F 951 653 1662  
www.babcocklabs.com

NELAP no. 02101CA  
CA ELAP no. 1156  
EPA no. CA00102





E.S.BABCOCK & Sons, Inc.

Environmental Laboratories est. 1906

Page 2 of 4- Organic Chemicals Form

Sample ID No. A8L2460-01

TEST METHOD	CHEMICAL ALL CHEMICALS REPORTED ug/L	ENTRY #	ANALYSES RESULTS	MCL ug/L	DLR
EPA 524.2	Chlorobenzene	34301	< 0.5	70	0.50
EPA 524.2	Styrene	77128	< 0.5	100	0.50
EPA 524.2	1,1,2,2-Tetrachloroethane	34516	< 0.5	1	0.50
EPA 524.2	Tetrachloroethene	34475	< 0.5	5	0.50
EPA 524.2	Toluene	34010	< 0.5	150	0.50
EPA 524.2	1,2,4-Trichlorobenzene	34551	< 0.5	5	0.50
EPA 524.2	1,1,1-Trichloroethane	34506	< 0.5	200	0.50
EPA 524.2	1,1,2-Trichloroethane	34511	< 0.5	2	0.50
EPA 524.2	Trichloroethene	39180	< 0.5	5	0.50
EPA 524.2	Trichlorofluoromethane	34488	< 5	150	5.0
EPA 524.2	Trichlorotrifluoroethane	81611	< 10	1200	10
EPA 524.2	Vinyl Chloride	39175	< 0.5	0.5	0.50
EPA 524.2	Xylenes (m+p)	A-014	< 0.5		0.50
EPA 524.2	Xylenes (ortho)	77135	< 0.5		0.50
EPA 524.2	Xylenes (Total)	81551	< 0.5	1750	0.50
EPA 504.1	Dibromochloropropane	38761	< 0.01	0.2	0.010
EPA 504.1	Ethylene dibromide	77651	< 0.02	0.05	0.020
EPA 508	Endrin	39390	< 0.1	2	0.10
EPA 508	Lindane	39340	< 0.2	0.2	0.20
EPA 508	Methoxychlor	39480	< 10	30	10
EPA 508	Toxaphene	39400	< 1	3	1.0
EPA 508	Chlordane	39350	< 0.1	0.1	0.10
EPA 525.2	DEH-Phthalate	39100	< 3	4	3.0
EPA 508	Heptachlor	39410	< 0.01	0.01	0.010
EPA 508	Heptachlor Epoxide	39420	< 0.01	0.01	0.010
EPA 507	Atrazine	39033	< 0.5	1	0.50
EPA 507	Molinate	82199	< 2	20	2.0
EPA 507	Simazine	39055	< 1	4	1.0
EPA 507	Thiobencarb	A-001	< 1	70	1.0
EPA 507	Alachlor	77825	< 1	2	1.0
EPA 515.3	Bentazon	38710	< 2	18	2.0
EPA 525.2	Benzo(a)pyrene	34247	< 0.1	0.2	0.10
EPA 515.3	2,4-D	39730	< 10	70	10
EPA 515.3	2,4,5-TP Silvex	39045	< 1	50	1.0
EPA 515.3	Dalapon	38432	< 10	200	10
EPA 515.3	Dinoseb	81287	< 2	7	2.0

Page 5 of 8 of Complete Report

mailing  
P.O. Box 432  
Riverside, CA 92502-0432

location  
6100 Quail Valley Court  
Riverside, CA 92507-0704

P 951 653 3351  
F 951 653 1662  
www.babcocklabs.com

NELAP no. 02101CA  
CA ELAP no. 1156  
EPA no. CA00102



**E.S.BABCOCK & Sons, Inc.**  
Environmental Laboratories *est. 1906*

Page 3 of 4- Organic Chemicals Form

Sample ID No. A8L2460-01

TEST METHOD	CHEMICAL ALL CHEMICALS REPORTED ug/L	ENTRY #	ANALYSES RESULTS	MCL ug/L	DLR
EPA 525.2	DEH-Adipate	A-026	< 5	400	5.0
EPA 548.1	Endothall	38926	< 45	100	45
EPA 508	Hexachlorobenzene	39700	< 0.5	1	0.50
EPA 508	Hexachlorocyclopentadiene	34386	< 1	50	1.0
EPA 515.3	Pentachlorophenol	39032	< 0.2	1	0.20
EPA 515.3	Pichloram	39720	< 1	500	1.0
EPA 508	Polychlorinated Biphenyls (Total PCB's)	39516	< 0.5	0.5	0.50

UNREGULATED ORGANIC CHEMICALS

EPA 508	Aldrin	39330	< 0.075		0.075
EPA 508	Dieldrin	39380	< 0.02		0.020
EPA 508	Propachlor	38533	< 0.5		0.50
EPA 515.3	Dicamba	82052	< 1.5		1.5
EPA 524.2	1,1,1,2-Tetrachloroethane	77562	< 0.5		0.50
EPA 524.2	1,1-Dichloropropene	77168	< 0.5		0.50
EPA 524.2	1,2,3-Trichlorobenzene	77613	< 0.5		0.50
EPA 524.2	1,2,4-Trimethylbenzene	77222	< 0.5		0.50
EPA 524.2	1,3,5-Trimethylbenzene	77226	< 0.5		0.50
EPA 524.2	1,3-Dichlorobenzene	34566	< 0.5		0.50
EPA 524.2	1,3-Dichloropropane	77173	< 0.5		0.50
EPA 524.2	2,2-Dichloropropane	77170	< 0.5		0.50
EPA 524.2	2-Butanone(MEK-EPA 8260)	81595	< 5		5.0
EPA 524.2	2-Chlorotoluene	A-008	< 0.5		0.50
EPA 524.2	4-Chlorotoluene	A-009	< 0.5		0.50
EPA 524.2	4-Methyl-2-Pentanone(MIBK)	81596	< 5		5.0
EPA 524.2	Bis(2-chloroethyl)ether (Non-NELAP)	34273	< 5		5.0
EPA 524.2	Bromobenzene	81555	< 0.5		0.50
EPA 524.2	Bromochloromethane	A-012	< 0.5		0.50
EPA 524.2	Bromomethane	34413	< 0.5		0.50
EPA 524.2	Chloroethane	34311	< 0.5		0.50
EPA 524.2	Chloromethane	34418	< 0.5		0.50
EPA 524.2	Dibromomethane	77596	< 0.5		0.50
EPA 524.2	Dichlorodifluoromethane	34668	< 0.5		0.50
EPA 524.2	Hexachlorobutadiene	34391	< 0.5		0.50
EPA 524.2	Isopropylbenzene	77223	< 0.5		0.50
EPA 524.2	Naphthalene	34696	< 0.5		0.50
EPA 524.2	n-Butylbenzene	A-010	< 0.5		0.50

Page 6 of 8 of Complete Report

*mailing*  
P.O. Box 432  
Riverside, CA 92502-0432

*location*  
6100 Quail Valley Court  
Riverside, CA 92507-0704

P 951 653 3351  
F 951 653 1662  
www.babcocklabs.com

NELAP no. 02101CA  
CA ELAP no. 1156  
EPA no. CA00102



E.S.BABCOCK & Sons, Inc.  
Environmental Laboratories *est. 1906*

Page 4 of 4- Organic Chemicals Form

Sample ID No. A8L2460-01

TEST METHOD	CHEMICAL ALL CHEMICALS REPORTED ug/L	ENTRY #	ANALYSES RESULTS	MCL ug/L	DLR
EPA 524.2	n-Propylbenzene	77224	< 0.5		0.50
EPA 524.2	p-Isopropyltoluene	A-011	< 0.5		0.50
EPA 524.2	sec-Butylbenzene	77350	< 0.5		0.50
EPA 524.2	tert-Butylbenzene	77353	< 0.5		0.50

Page 7 of 8 of Complete Report

*mailing*  
P.O. Box 432  
Riverside, CA 92502-0432

*location*  
6100 Quail Valley Court  
Riverside, CA 92507-0704

P 951 653 3351  
F 951 653 1662  
www.babcocklabs.com


NELAP no. 02101CA  
CA ELAP no. 1156  
EPA no. CA00102

RADIOACTIVITY ANALYSIS (9/99)

Date of Report: 09/01/12  
 Laboratory  
 Name: TRUESDAIL LABS  
 Name of Sampler: Mark Ban  
 Date/Time Sample  
 Collected: 08/12/23/0916

Sample ID No. 980861/A8L2466-01

Signature Lab

Director: 

Employed By: Hi-Desert WD

Date/Time Sample

Date Analyses

Received @ Lab: 08/12/30/1030

Completed: 09/01/08

System

System

Name: HI DESERT WD

Number: 3610073

Name or Number of Sample Source: WELL 24E

\*\*\*\*\*  
 \* User ID: TAN Station Number: 3610073-023 \*  
 \* Date/Time of Sample: |08|12|23|0916| Laboratory Code: 9469 \*  
 \* YY MM DD TTTT YY MM DD \*  
 \* Date Analysis completed: |09|01|08| \*  
 \* Submitted by: \_\_\_\_\_ Phone #: \_\_\_\_\_ \*  
 \*\*\*\*\*

MCL REPORT UNITS	CHEMICAL	STORET CODE	ANALYSES RESULTS	DLR
	pCi/L TITLE 22 CALIFORNIA CODE OF REGULATIONS			
	pCi/L SECTION 64442 (22 CCR 64442)			
15	pCi/L Gross Alpha	01501	9.36	3.0
	pCi/L Gross Alpha Counting Error	01502	1.81	
	pCi/L Gross Alpha MDA95 *	A-072		
20	pCi/L Uranium	28012		1.0
	pCi/L Uranium Counting Error	A-028		
	pCi/L Uranium MDA95	A-073		
	pCi/L Radium 226	09501		1.0
	pCi/L Radium 226 Counting Error	09502		
	pCi/L Radium 226 MDA95	A-074		
	pCi/L Radium 228	11501		1.0
	pCi/L Radium 228 Counting Error	11502		
	pCi/L Radium 228 MDA95	A-075		
5	pCi/L Ra 226 + Ra 228, Combined	11503		
	pCi/L Ra 226 + Ra 228 Counting Error, Combined	11504		
	pCi/L Ra 226 + Ra 229 MDA95, Combined	A-076		
	pCi/L TITLE 22 CALIFORNIA CODE OF REGULATIONS			
	pCi/L SECTION 64443 (22 CCR 64443)			
50	pCi/L Gross Beta	03501		4.0
	pCi/L Gross Beta Counting Error	03502		
	pCi/L Gross Beta MDA95	A-077		
4	pCi/L Gross Beta, Calculated Dose Equivalent *	A-071		
8	pCi/L Strontium 90	13501		2.0
	pCi/L Strontium 90 Counting Error	13502		

pCi/L Strontium 90 MDA95	A-078	
20000 pCi/L Tritium	07000	1000
pCi/L Tritium Counting Error	07001	
pCi/L Tritium MDA95	A-079	
pCi/L RADON		
pCi/L Radon 222	82303	100.0
pCi/L Radon 222 Counting Error	82302	
pCi/L		
pCi/L *MDA95 is Minimum Detectable Activity at		
pCi/L the 95% confidence level, per		
pCi/L 22 CCR 64442 and 64443.		
pCi/L		
pCi/L **Gross Beta, Calculated Total Body or		
pCi/L Organ Dose Equivalent, Per 22 CCR 64443		
pCi/L		

---

EMS Laboratories  
117 W. Bellevue Dr.  
Pasadena, Ca 91105

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

Date of Report: 09/01/06

Sample ID No. A8L2466-01

Laboratory

Signature Lab

Name: EMS LABORATORIES INC.

Director: RS / for Bernice Kolk

Name of Sampler: Mark Ban

Employed By: Hi-Desert Water District

Date/Time Sample

Date/Time Sample

Date Analyses

Collected: 08/12/23/0916

Received @ Lab: 08/12/30/1035

Completed: 09/01/05

System

System

Name: HI DESERT WD

Number: 3610073

Name or Number of Sample Source: WELL 24E

\*\*\*\*\*

\* User ID: TAN

Station Number: 3610073-023

\*

\* Date/Time of Sample: |08|12|23|0916|

Laboratory Code: 0004

\*

\* YY MM DD TTTT

YY MM DD

\*

\* Submitted by: [Signature]

Date Analysis completed: |09|01|05|

\*

Phone #: 626-568-4065

\*

\*\*\*\*\*

PAGE 1 OF 1

ADDITIONAL ANALYSES

MCL	REPORTING	CHEMICAL	ENTRY	ANALYSES	DLR
	UNITS		#	RESULTS	
7	MFL	Asbestos (MFL)	81855	< .20	.20

+ Indicates Secondary Drinking Water Standards

Laboratory comments and description of any additional components found:

Sample was UV ozonated for 3 hours and filtered 08-12-30 at 1420

ORGANIC CHEMICAL ANALYSIS (9/99)

Date of Report: 09/01/06

Sample ID No.1087031001

Laboratory

Signature Lab

Name: PACE ANALYTICAL - MINNEAPOLIS

Director: William H. Hinkle

Name of Sampler: Mark Ban

Employed By: Hi-Desert Water Dist.

Date/Time Sample

Date/Time Sample

Date Analyses

Collected: 08/12/23/0916

Received @ Lab: 08/12/30/0945

Completed: 09/01/04

System

System

Name: HI DESERT WD

Number: 3610073

Name or Number of Sample Source: WELL 24E

\*\*\*\*\*

\* User ID: TAN

Station Number: 3610073-023 \*

\* Date/Time of Sample: |08|12|23|0916|

Laboratory Code: 2155 \*

\* YY MM DD TTTT

YY MM DD \*

\* Date Analysis completed: |09|01|04| \*

\* Submitted by: E.S. Babcock as APL2466-01 Phone #: \_\_\_\_\_ \*

\*\*\*\*\*

Page 1 of 1

REGULATED ORGANIC CHEMICALS

TEST	CHEMICAL	ENTRY	ANALYSES	MCL	DLR
METHOD	ALL CHEMICALS REPORTED ug/L	#	RESULTS	ug/L	ug/L
1613	2,3,7,8-TCDD (Dioxin) Units=picogram/L	34676	ND	30	5.00

North Coast Laboratories, LTD.  
5680 West End Road  
Arcata, CA 95521

EDT

**AGRICULTURAL CHEMICAL AND MISCELLANEOUS ORGANIC ANALYSIS (10/97)**

Date of Report: 1/13/09

Sample ID No. 0812645/A8L2466-01

Laboratory Name: NORTH COAST LABS

Signature Lab Director: \_\_\_\_\_

Name of Sampler: Mark Ban

Employed by: HI DESERT WD

Date/Time Sample Collected: 12/23/08 09:16:00

Date Sample Received: 12/31/08

Data Analysis Completed: 1/6/09

System Name: HI DESERT WD

System number: 3610073

Sample Source Name: WELL 24E

User ID: TAN

Station number: 3610073-023

Date/Time Sample Collected: 12/23/08 09:16:00

Laboratory Code: 3334

Data Analysis Completed: 1/6/09

Submitted by: \_\_\_\_\_

Phone: \_\_\_\_\_

Page 1 of 1

TEST METHOD	CHEMICAL ALL CHEMICALS REPORTD ug/L	ENTRY #	ANALYSES RESULTS	MCL ug/L	DLR ug/L
531.1	Methiocarb (MESUROL)	38500	< 5.0		
531.1	Propoxur (BAYGON)	38537	< 5.0		

**North Coast Laboratories, LTD.**  
**5680 West End Road**  
**Arcata, CA 95521**  
**ORGANIC CHEMICAL ANALYSIS (9/99)**

EDT

Date of Report: 1/13/09

Sample ID No. 0812645/A8L2466-01

Laboratory Name: NORTH COAST LABS

Signature Lab Director: \_\_\_\_\_

Name of Sampler: Mark Ban

Employed by: HI DESERT WD

Date/Time Sample Collected: 12/23/08 09:16:00

Date Sample Received: 12/31/08

Data Analysis Completed: 1/6/09

System Name: HI DESERT WD

System number: 3610073

Sample Source Name: WELL 24E

User ID: TAN	Station number: 3610073-023
Date/Time Sample Collected: 12/23/08 09:16:00	Laboratory Code: 3334
Submitted by: _____	Data Analysis Completed: 1/6/09
	Phone: _____

Page 1 of 1

REGULATED ORGANIC CHEMICALS

TEST METHOD	CHEMICAL ALL CHEMICALS REPORTD ug/L	ENTRY #	ANALYSES RESULTS	MCL ug/L	DLR ug/L
531.1	Carbofuran (FURADAN)	81405	ND	18	5.00
547	Glyphosate	79743	ND	700	25.00
531.1	Oxamyl (Vydate)	38865	ND	50	20.00

UNREGULATED ORGANIC CHEMICALS

531.1	Aldicarb (TEMIK)	39053	ND		3.00
531.1	Aldicarb Sulfone	A-020	ND		4.00
531.1	Aldicarb Sulfoxide	A-019	ND		3.00
531.1	Carbaryl (Sevin)	77700	ND		5.00
531.1	3-Hydroxycarbofuran	A-021	ND		3.00
531.1	Methomyl	39051	ND		2.00

Date: 13-Jan-2009  
WorkOrder: 0812645

# ANALYTICAL REPORT

Client Sample ID: A8L2466-01  
Lab ID: 0812645-01A

Received: 12/31/08

Collected: 12/23/08 09:16

Test Name: Glyphosate

Reference: EPA 547

<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Units</u>	<u>DF</u>	<u>Extracted</u>	<u>Analyzed</u>
Glyphosate	ND	10	µg/L	1.0	1/5/09	1/6/09

Client Sample ID: A8L2466-01  
Lab ID: 0812645-01C

Received: 12/31/08

Collected: 12/23/08 09:16

Test Name: N-methyl -carbamoyloximes and carbamates

Reference: EPA 531.1

<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Units</u>	<u>DF</u>	<u>Extracted</u>	<u>Analyzed</u>
Aldicarb Sulfoxide	ND	3.0	µg/L	1.0	1/6/09	1/7/09
Aldicarb Sulfone	ND	4.0	µg/L	1.0	1/6/09	1/7/09
Oxamyl	ND	5.0	µg/L	1.0	1/6/09	1/7/09
Methomyl	ND	2.0	µg/L	1.0	1/6/09	1/7/09
3-OH-Carbofuran	ND	3.0	µg/L	1.0	1/6/09	1/7/09
Aldicarb	ND	3.0	µg/L	1.0	1/6/09	1/7/09
Propoxur	ND	5.0	µg/L	1.0	1/6/09	1/7/09
Carbofuran	ND	5.0	µg/L	1.0	1/6/09	1/7/09
Carbaryl	ND	5.0	µg/L	1.0	1/6/09	1/7/09
Methiocarb	ND	5.0	µg/L	1.0	1/6/09	1/7/09
Surrogate: BDMC	125	76.8-114	% Rec	1.0	1/6/09	1/7/09