

**BIG HORN DESERT VIEW WATER AGENCY**

**ADDENDUM NO. 6**

**PUMP REPLACEMENT PROJECT**

**December 18, 2018**

**REVISION TO SPECIFICATIONS:**

Add the following to Subsection A (2) at SECTION E – SPECIAL CONDITIONS:

“Existing pump settings” are:

Well No. 7: 225 feet

Well No. 8: 390 feet

Well No. 9: 350 feet

**REVISION TO PLANS:**

On the 30 HP and 75 HP Well Pump Starter Panel Diagram, the “Submersible Well Pump Motor” speed is changed to “3450 RPM”.

ALL BIDDERS SHALL INDICATE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND INCLUDE THIS SHEET WITH THEIR BID.

---

CONTRACTOR’S AUTHORIZED REPRESENTATIVE’S SIGNATURE HERE

---

DATE