

BIGHORN DESERT VIEW WATER AGENCY

ADDENDUM NO. 7

PUMP REPLACEMENT PROJECT

January 3, 2019

REVISION TO SPECIFICATIONS:

Make the following revision to DIVISION16, ELECTRICAL:

All enclosures shall be standard NEMA 3R type enclosure, not stainless steel as identified in the specification.

REVISION TO PLANS:

Per Addendum No. 6, on the 30 HP and 75 HP Well Pump Starter Panel Diagram, the “Submersible Well Pump Motor” speed is changed to “3450 RPM”.

In addition, new starter enclosure circuit breakers shall be adjustable trip type.

ALL BIDDERS SHALL INDICATE RECEIPT OF THIS ADDENDUM BY SIGNING BELOW AND INCLUDE THIS SHEET WITH THEIR BID.

CONTRACTOR’S AUTHORIZED REPRESENTATIVE’S SIGNATURE HERE

DATE